



## CONFORMITY CERTIFICATE

08/X29/1/6277404-1001-1, rev.1

ICAO, Doc 9157-AN/901, Part 5  
IEC 61823:2002  
FAA AC 150/5345-47C

### CERTIFIES:

That, to request of the Company: Airsafe Airport Equipment Co. Ltd proceeds to the inspection, review and documental study technical equipment, Isolation Transformers for airports lighting model ITF:

<u>Reference</u>	<u>Wattage [W]</u>
ITF-015-6.6/6.6	10/15
ITF-025-6.6/6.6	20/25
ITF-045-6.6/6.6	30/45
ITF-065-6.6/6.6	65
ITF-100-6.6/6.6	100
ITF-150-6.6/6.6	150
ITF-200-6.6/6.6	200
ITF-300-6.6/6.6	300

That all the foregoing, and in view of the results obtained, is considered that:  
The Isolating Transformers model ITF above referenced, manufactured by Airsafe Airport Equipment Co. Ltd, destined for airports lighting applications, FULFIL SATISFACTORILY the demands and requirements of the standards and technical requisites that referred in the present document, and specifically the specifications of the IEC 61823, FAA AC 150/5345-47C and ICAO 9157-AN/901:

Model	ICAO	FAA	IEC
	Result	Result	Result
ITF-015-6.6/6.6	Not Apply	Satisfactory	Not Apply
ITF-025-6.6/6.6	Not Apply	Satisfactory	Not Apply
ITF-045-6.6/6.6	Satisfactory	Satisfactory	Satisfactory
ITF-065-6.6/6.6	Satisfactory	Satisfactory	Satisfactory
ITF-100-6.6/6.6	Satisfactory	Satisfactory	Satisfactory
ITF-150-6.6/6.6	Not Apply	Satisfactory	Satisfactory
ITF-200-6.6/6.6	Satisfactory	Satisfactory	Satisfactory
ITF-300-6.6/6.6	Satisfactory	Satisfactory	Satisfactory

And for the record for the appropriate purposes is issued and signed this Certification in Barcelona, January 2<sup>nd</sup>, 2019.

Inspector Bureau Veritas  
Laura Arcas

